

Photovoltaic (PV) incident response tactics

Take the following precautions when responding to a PV system fire:

1. **Confirm National Grid has been notified.** Work with them in a unified command structure to interrupt electricity production and isolate the system from the power grid.
2. **Size up the hazard to identify system type and location.** Walk 360 degrees around the structure to identify solar components that may not be immediately apparent, such as arrays, inverters and control switchgear.
3. **Communicate the presence of a PV system to all personnel operating on the incident scene.** The Incident Commander should notify the dispatcher, who can sound an alert to all operating frequencies assigned to the incident.
4. **Utilize full PPE including SCBA.** Burning PV panels may release toxic and potentially carcinogenic particulates. Be sure to fully decontaminate turnout gear after the incident concludes.
5. **Always consider PV system components to be energized.** PV system components may carry voltage even after the main disconnect switch has separated the system from the grid and eliminated large-scale electrical production.
6. **Maintain a safe distance of at least 3 feet from all PV system components.** Voltage can be transferred to you via direct contact or through tools that contact the array, inverters or wiring. Maintain 3 feet as a minimum safety clearance.
7. **Use extinguishing agents on system components only after the system has been electrically isolated.** Contain a small fire utilizing Class C extinguishing agents such as dry chemical or carbon dioxide. For larger fires where Class C agents are impractical, apply water in a 30-degree fog pattern at 100 psi, from a distance of at least 30 feet.
8. **Be alert for battery hazards.** Consider both the stored energy and the hazardous materials within the battery itself. Fires involving batteries should be addressed as a hazardous materials release. Wear full PPE/SCBA, and extinguish utilizing Class C agents such as CO₂ or dry chemical. **Do NOT use water!**
9. **Be alert for structural failure.** Roof-mounted PV systems add weight to a structure. Stay at the corners of the structure, or beyond the collapse zone (1.5 times the height of the structure) whenever possible.
10. **Remain vigilant during overhaul activities.** Make sure all conduits and components have been appropriately identified and isolated. Work with National Grid personnel to permanently secure the system and disable any potential for the system to backfeed voltage, into either the occupancy or the power grid.